

SPEC WRITER'S GUIDE

EW SERIES

CATALOG NO.
EW101B
EW103B
EW120B
EW201B
EW103B-C
EW103B-Y
EW120B-C
EW120B-Y
EW201B-Y

EW SERIES – 1. Furnish and install a TORK digital time switch with (40 Amp SPST contacts, model EW101B, EW210B) (40 Amp DPST contacts, model EW103B) (30 Amp SPDT contacts, model EW120B). 2. Unit shall be capable of 20 set points. 3. Unit shall be capable of a different schedule each day of the week. 4. (Model EW201B ONLY) Unit shall be capable of being a 2 channel maintained or a 1 channel momentary. 5. Unit shall have automatic Daylight Savings Time and Leap Year compensation. 6. Unit shall program in AM/PM format. 7. Unit shall have LCD display. 8. Unit shall have permanent schedule retention. 9. Unit real time clock shall be retained by super capacitor for 100 hours in a power failure. 10. Unit shall be capable of manual override ON or OFF either to the next scheduled event or permanently. 11. Unit shall have a NEMA 3R Indoor/Outdoor plastic enclosure. 12. Unit shall have Load Status indication. 13. Unit shall have Power Failure indication. 14. To order specify TORK Model EW101B (EW103B) (EW120B) (EW201B)