

SPEC WRITER'S GUIDE

EWZ SERIES

CATALOG NO.
EWZ101
EWZ103
EWZ120
EWZ201
EWZ101-MB
EWZ103-MB
EWZ120-MB
EWZ201-MB

EWZ SERIES – 1. Furnish and install TORK digital time switch with (40 AMP contacts, models EWZ101, EWZ201) (40 Amp DPST contacts, model EWZ103) (30 AMP contacts, model EWZ120). 2. Unit shall be capable of 20 set points. 3. Unit shall be capable of a different schedule for each day of the week. 4. Unit shall be have astronomic option adjustable from 1°- 60° northern or southern latitudes. 5. Unit shall be have astronomic option with offset up to 4 hours and 59 minutes, before or after sunrise. 6. (Model EWZ201 ONLY) Unit shall be capable of being a 2 channel maintained or a 1 channel momentary. 7. Unit shall have automatic Daylight Savings Time and Leap Year compensation. 8. Unit shall program in AM/PM format. 9. Display shall be of LCD type. 10. Unit shall have permanent schedule retention. 11. Unit real time clock shall be retained by capacitor for 100 hours in a power failure. 12. Unit shall be capable of manual override ON or OFF either in the next scheduled event or permanently. 13. Unit shall have NEMA Type 3 indoor/outdoor enclosure as standard. 14. Unit shall have Load Status indication. 15. Unit shall have Power Failure indication. 16. To order specify TORK Model EWZ101 (EWZ103) (EWZ120) (EWZ201).