

# TORK®

## DIGITAL CONTROLS

### SPEC WRITER'S GUIDE

## LC200 SERIES

CATALOG  
NO.

LC200

LC200M

Furnish and install an electronic light sensor and control with dual outputs for two lighting zones. Each output shall be capable of a different user settable turn ON light level set points from 2 to 100 footcandles. Turn ON to turn OFF ratio shall be 1:2. Controller shall also offer two digital inputs, which can accept a contact closure from an independent time switch or EMS system, thereby allowing for independent time of day control.