

### SPEC WRITER'S GUIDE

## ELC SERIES

| CATALOG NO. |
|-------------|
| ELC74       |
| ELC78       |
| ELC712      |
| TLS-R       |
| LCS115M     |

Installer shall furnish and install Tork ELC74, ELC78 eight channel (or ELC712 Twelve Channel) electronic time control. The control shall have 24 hour, 7 day, 365 day or astronomic capability with 128 events available. It shall also have 4 user-definable durations and duty cycle lengths plus automatic daylight saving time and leap year adjustments. Control shall have remote override capabilities (timed, toggle or enable type). Control shall have keyboard override until overridden again or until next event is reached. It shall be capable of switching loads based on user-definable temperature and light levels with 32 events available. Control shall have momentary (latching relay) capability and shall have astronomic features plus 30 definable holidays and 6 pre-programmed holidays. Control shall provide 2 days of power outage carry-over without a battery. Control shall provide 10 years of power outage protection with a battery. The digital time display shall be 3/4" in height. Clock format shall be selectable, allowing a choice of 12 hour (AM/PM) or 24 hour format. Control shall be capable of interfacing (sending and receiving data) with a personal computer. Power input terminals shall have the capability to accommodate #12 to #18 AWG wire. Control shall be housed in a NEMA 1, lockable steel enclosure, to guard against vandalism or tampering.